

## **7 Cedars Casino Copper, Lead and Water Quality Parameter Monitoring 2015**

When collecting copper and lead samples, at a minimum also collect the following Water Quality Parameter (WQP) samples:

- pH – measured at the tap
  - temperature – measured at the tap
  - alkalinity – analyzed by lab
  - calcium – analyzed by lab
  - conductivity – analyzed by lab
- 
- 2 sets of WQP samples are to be collected at the entry point to the distribution system – taken 1 week apart
  - 2 sets of samples are to be collected from one of the lead/copper sites located in the Casino – taken 1 week apart